



**DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY**  
**DEPARTMENT OF WATER SERVICES**  
3900 Donaldson Pl, N.W. WASHINGTON DC 20016

**Lead and Copper Compliance Report**  
**July - December 2006**

Table 1 summarizes the compliance results for the monitoring period July through December 2006.

**Table 1. July - December 2006 Lead and Copper Compliance Results**

<b>Number of Samples</b>	
Total	106
<b>90th Percentile First Draw Concentrations</b>	
Lead mg/L	0.012
Copper mg/L	0.078
<b>Service Line Materials</b>	
Full Lead	76%
Partial Lead	24%

The appendices contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
  - Table A.1 First Draw Lead Results
  - Table A.2 First Draw Copper Results
- Appendix B: Non-Regulated Lead Data
  - Table B.1 Second Draw Lead Results
  - Table B.2 Second Draw Copper Results
  - Table B.3 Customer Requested Lead Samples
  - Table B.4 Lead Service Line Replacement Samples
- Appendix C: Sample Kit Distribution
  - Table C.1 Sample Kit Distribution – July to December 2006
  - Table C.2 Sample Kits Not Returned
  - Table C.3 Samples Returned and Rejected for Compliance Analysis
  - Table C.4 Addresses Not Receiving Sample Kits July to December 2006
- Appendix D: Locations Removed from Routine List



## Appendix A – Lead and Copper Compliance Data

**Table A.1 Lead Results**

No.	Address	Service Line Material	Lead (mg/L) 1st Draw
1	████ TRINIDAD AVE NE	Full Lead	0.000
2	████ Park St NE	Full Lead	0.000
3	████ 11th St NE	Full Lead	0.000
4	████ S ST NW	Partial Lead	0.000
5	████ 11th St SE	Full Lead	0.000
6	████ HALL PL NW	Full Lead	0.000
7	████ 8TH ST NW	Partial Lead	0.001
8	████ FRANKLIN ST NE	Full Lead	0.001
9	████ Wallach Pl NW	Full Lead	0.001
10	████ MORRISON ST NW	Full Lead	0.001
11	████ BRANDYWINE ST NW	Partial Lead	0.001
12	████ 14TH ST NW	Full Lead	0.001
13	████ PARK ST NE	Partial Lead	0.001
14	████ Longfellow St NW	Full Lead	0.001
15	████ Kennedy St NW	Full Lead	0.001
16	████ Quebec Pl NW	Full Lead	0.002
17	████ 37TH ST NW	Full Lead	0.002
18	████ WARREN ST NW	Full Lead	0.002
19	████ COLUMBIA RD NW	Full Lead	0.002
20	████ 21st ST NW	Full Lead	0.002
21	████ ATLANTIC ST SE	Full Lead	0.002
22	████ 7TH ST NW	Partial Lead	0.002
23	████ MONROE ST NW	Partial Lead	0.002
24	████ Massachusetts Ave SE	Partial Lead	0.002
25	████ RENO RD NW	Partial Lead	0.002
26	████ 14TH ST SE	Full Lead	0.002
27	████ F St NE	Full Lead	0.002
28	████ T St SE	Full Lead	0.002
29	████ GIRARD ST NW	Partial Lead	0.002
30	████ 10th St NE	Full Lead	0.002
31	████ NEWPORT PL NW	Full Lead	0.002
32	████ COLORADO AVE NW	Full Lead	0.002
33	████ Trinidad Ave NE	Full Lead	0.003
34	████ ALTON PL NW	Partial Lead	0.003
35	████ Madison St NW	Full Lead	0.003



No.	Address	Service Line Material	Lead (mg/L) 1st Draw
36	MONROE ST NW	Partial Lead	0.003
37	P ST NW	Full Lead	0.003
38	13TH ST NW	Full Lead	0.003
39	MONROE ST NW	Partial Lead	0.003
40	BRENTWOOD RD NE	Full Lead	0.003
41	SUMMIT PL NE	Partial Lead	0.003
42	TENNESSEE AVE NE	Full Lead	0.003
43	WEBSTER ST NW	Full Lead	0.003
44	HAMLIN ST NE	Full Lead	0.003
45	ALABAMA AVE SE	Full Lead	0.003
46	HAMILTON ST NW	Partial Lead	0.003
47	BROWN St NW	Partial Lead	0.004
48	TENNESSEE AVE NE	Full Lead	0.004
49	E ST SE	Full Lead	0.004
50	DOUGLAS ST NE	Partial Lead	0.004
51	39TH ST NW	Full Lead	0.004
52	Irving St NE	Full Lead	0.004
53	Ives Pl SE	Full Lead	0.005
54	PORTER ST NW	Full Lead	0.005
55	POTOMAC AVE SE	Partial Lead	0.005
56	15TH ST NW	Full Lead	0.005
57	50th St NE	Full Lead	0.005
58	13TH ST SE	Full Lead	0.005
59	BILTMORE ST NW	Full Lead	0.005
60	BILTMORE ST NW	Full Lead	0.005
61	INGOMAR ST NW	Full Lead	0.005
62	UHLAND TER NE	Full Lead	0.006
63	JEFFERSON ST NW	Partial Lead	0.006
64	INDEPENDENCE AVE SE	Partial Lead	0.006
65	GREENWICH PKWY NW	Full Lead	0.006
66	BILTMORE ST NW	Full Lead	0.006
67	13th St SE	Full Lead	0.006
68	KEARNEY ST NE	Partial Lead	0.006
69	30TH ST NW	Partial Lead	0.006
70	5TH ST NW	Full Lead	0.006
71	S ST SE	Full Lead	0.006
72	16TH ST NE	Full Lead	0.007
73	JACKSON ST NE	Partial Lead	0.007
74	Irving St NW	Full Lead	0.007
75	BUCHANAN ST NW	Full Lead	0.007

No.	Address	Service Line Material	Lead (mg/L) 1st Draw
76	████ FLORAL ST NW	Full Lead	0.007
77	████ 38TH ST NW	Full Lead	0.007
78	████ 9TH ST NW	Full Lead	0.007
79	████ SUMMIT PL NE	Full Lead	0.008
80	████ KLINGLE RD NW	Full Lead	0.008
81	████ Michigan Ave NE	Full Lead	0.008
82	████ TAYLOR ST NW	Partial Lead	0.008
83	████ VEAZEY ST NW	Full Lead	0.008
84	████ LOWELL ST NW	Full Lead	0.009
85	████ JEFFERSON ST NW	Full Lead	0.009
86	████ Madison St NW	Full Lead	0.010
87	████ Delafield PI NW	Full Lead	0.010
88	████ E Capitol St NE	Full Lead	0.010
89	████ 7TH ST NW	Full Lead	0.010
90	████ Bryant St NW	Full Lead	0.011
91	████ PORTER ST NW	Full Lead	0.011
92	████ IOWA AVE NW	Full Lead	0.012
93	████ BRANDYWINE ST NW	Full Lead	0.012
94	████ D ST SE	Partial Lead	0.012
<b>95<sup>1</sup></b>	<b>████ YUMA ST NW</b>	<b>Full Lead</b>	<b>0.012</b>
96	████ 3RD ST NE	Full Lead	0.012
97	████ FOREST LN NW	Full Lead	0.013
98	████ HARVARD ST NW	Full Lead	0.013
99	████ ALBEMARLE ST NW	Full Lead	0.013
100	████ 3RD ST NE	Full Lead	0.014
101	████ V ST NW	Full Lead	0.015
102	████ IOWA AVE NW	Full Lead	0.016
103	████ LONGFELLOW ST NW	Full Lead	0.016
104	████ I St NE	Partial Lead	0.017
105	████ RITTENHOUSE ST NW	Full Lead	0.019
106	████ GARRISON ST NW	Full Lead	0.020

Notes: All addresses meet Tier 1 criteria under 141.86(a)(3) as single family structures with either full or partial lead service lines based on WASA's customer information and service line inventory. Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

<sup>1</sup>Bolded data represents 1<sup>st</sup> draw 90<sup>th</sup> percentile.



